



Certificate of constancy of performance 0620-CPR-0216646-1



Issued 2024-04-01 Replaces -
First issued 2024-04-01 Page 1 of 3

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Pillar fire hydrants and Underground fire hydrants

Type and intended use: EN 14339: Underground fire hydrants
Level / Class: Not applicable
Method of declaration: EN 14339: Underground fire hydrants
Other Characteristics: Described on page 2

placed on the market under the name or trademark of

Rödhammarbolagen AB

and produced in the manufacturing plant

Rödhammarbolagen AB, Skogås, Sweden

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

EN 14339:2005

Under system 1 for the performances set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 1 April 2024 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performances of the declared essential characteristics, do not change, and the construction product and the manufacturing conditions in the plant or the factory production control itself are not modified.

Ron Scheepers
Managing director
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.

Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
NL.Kiwa.info@Kiwa.com
www.kiwa.nl

Manufacturer

Rödhammarbolagen AB
Vretvägen 11
14234 Skogås
Sweden
Tel +46 08 77 19 130
info@rodhammar.se
www.rodhammar.se

Manufacturing plant

Rödhammarbolagen AB
Vretvägen 11
14234 Skogås
Sweden
Tel +46 08 77 19 130
info@rodhammar.se
www.rodhammar.se

Notified Body No. 0620



Notified Body No.0620, Kiwa

Certificate of constancy of performance 0620-CPR-6122

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Underground and Pillar hydrants

Type of product: Fire Hydrant Cast Iron model 1939¹

Size outlet	DN 80
Size inlet	DN 100
Pressure	PN 16

¹ Provided that materials including lubricants in contact with water intended for human consumption comply with the National Regulations.

Marking

Compulsory specifications:

EN 14339, underground hydrants

- Indication of direction of opening;
- Number of turns required to start the flow and for full opening;
- Indication of DN;
- Indication of PN;
- Name or logo of the manufacturer;
- Date or code indicating the year of production;
- Reference to the applicable standard (EN 14339);
- Loose obturator (if applicable).

Method of marking:

- Non-erasable;
- visible after assembly.

APPLICATION AND USE

Application and use

The hydrants are intended for drinking water installations with a maximum working pressure of 1000 kPa and a maximum water temperature of 30°C.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Rödhammarbolagen AB
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.